



Remediation Plan Recommendations

For test points at or above 5 pbb lead content, per §160.077, secure water and discontinue use until remediated unless testing proves that flushing will provide water below 5ppb.

All sample points that failed the initial sampling have been remediated successfully.

Shown below are the test points with initial results in yellow and flush test results in green.

Initial	Flush	Remedial	Location	Remediation Recommendations
15.8	2.36	ND	WATER MAIN TEST POINT IN BASEMENT	No further action required
6.34	ND	ND	2ND SINK SCIENCE ROOM	
7.3	ND	ND	3RD SINK SCIENCE ROOM	
8.25	ND	ND	4TH SINK SCIENCE ROOM	
6.27	ND	ND	5TH SINK SCIENCE ROOM	
24	ND	ND	6TH SINK SCIENCE ROOM	
18.6	ND	ND	7TH SINK SCIENCE ROOM	
9.31	ND	ND	8TH SINK SCIENCE ROOM	
12.3	ND	ND	9TH SINK SCIENCE ROOM	

The next scheduled testing is 25% of the remediated items are required to be tested per year until all items have been retested. The next full cycle of testing will be in 2028-2029 school year.